

Mr. Mitchell Smith Superintendent Waste Water Treatment Plant 1501 W. Markland Ave. Kokomo, IN 46901

Dear Mr. Smith:

This letter is confirming our many excesses of zinc for this month. These excesses have been verbally reported to either Mark McGiver or yourself. The overages have been as follows:

Sample collected:	2/3/98	4.22
	2/5/98	6.86
	2/10/98	8.42
	2/12/98	9.36
	2/17/98	3.83
	2/19/98	7.30
	2/24/98	4.11
Resamples collected	2/13/98	9.16
	2/18/98	4.39
	2/20/98	6.27
	2/23/98	5.81

These results are after a thorough cleaning of all tanks and the reversal of our rinse water overflow. All of these changes that we have done thus far have gotten us further out of compliance. As you should know this is the reason that Milbank Mfg., is going to have a treatment facility installed.

The persons involved will be here March 3, for a discussion and confirming of plans for this system.

If you have any questions regarding this matter, feel free to contact me.

Sincerely,

MILBANK MFG., CO., INC.

Richard L. Tyler Plant Manager